


VA



U.S. Department
of Veterans Affairs

Office of Construction &
Facilities Management

Many VA Hospitals are in Seismic Regions



Seismic Design Requirements

AUGUST 2013

H-18-8

FOREWORD

Background

In 1971, after the San Fernando earthquake when two VA buildings collapsed, VA began to undertake a full seismic safety program. Title 38 - United States Code, section 8105 required the Secretary to assure that each medical facility constructed or altered shall be of construction that is resistant to fire, earthquake, and other natural disasters. This initiated the creation of the Secretary's Advisory Committee on Structural Safety of VA Facilities, which formally approved in 1975 the original VA Seismic Design document, H-08-8, Earthquake Resistant Design Requirements for VA Facilities. These requirements were developed with the concept that all VA Essential Facilities must remain in operation after an earthquake and were far in advance of National Codes.

This document is periodically updated and revised. The revision of H-08-8 to H-18-8 in 1995 was a major rewrite to bring VA seismic design requirements more in line with the updated national model codes. Further updates/revisions of minor nature were made in 1997, 1998, 2000, 2002, 2003, 2005, 2006, 2008, 2010, and 2011.

Current Revision Highlights:

- Reference of ASCE 396 changed to FEMA 396
- Modified definition of Ancillary Facilities slightly to define them as non-essential.
- Modified sections 3.7 to preclude exemption of non-structural elements in low seismicity and emphasize following section 4.0.

Note: A vertical bar is placed to the right of the revised sections.

Lloyd H. Siegel
Associate Executive Director
Office of Facilities Planning

August 2013

TABLE OF CONTENTS

1.0 Definitions..... 4

2.0 General..... 6

3.0 Modifications to Requirements of IBC for New
Critical and Essential Facilities 8

4.0 Elements of Structures, Nonstructural Components,
and Equipment Supported by Structures..... 11

5.0 Site Data for Critical and Essential Facilities 12

6.0 Commentary 14

7.0 Tables..... 16

8.0 Seismicity Map with Department of Veterans Affairs Medical Centers 25

1.0 DEFINITIONS

1.1 ASCE/SEI 41–06: Seismic Rehabilitation of Existing Buildings, American Society of Civil Engineers.

1.2 AISC 341: Seismic Provisions for Structural Steel Buildings, including Supplement No. 1 dated 2006, American Institute of Steel Construction.

1.3 ASCE 7: Minimum Design Loads for Buildings and Other Structures, American Society of Civil Engineers, Latest Edition

1.4 ASCE 31- 02: Seismic Evaluation of Existing Buildings, American Society of Civil Engineers.

1.5 FEMA 396: Incremental Seismic Rehabilitation of Hospital Buildings, American Society of Civil Engineers.

1.6 Category of Facilities:

- a) **Critical Facilities:** Buildings that are required to remain functional after an earthquake or other natural disaster such as hurricane, tornado, etc. These facilities include, but are not limited to, the occupancy categories listed as Critical Facilities in Table 1, and they shall be assigned to IBC Occupancy Category IV.
- b) **Essential Facilities:** Buildings that must remain operational with minor repairs after an earthquake or other natural disaster such as hurricane, tornado, etc. These facilities include, but are not limited to occupancy categories listed as Essential Facilities in Table 2, and they shall be assigned to IBC Occupancy Category III.
- c) **Ancillary Facilities:** These facilities include, but are not limited to, the occupancy categories listed as Ancillary Facilities in Table 3. All ancillary facilities shall be designated as non-essential facilities and shall be assigned to IBC Occupancy Category II.

1.7 IBC: International Building Code, Latest Edition.

1.8 Occupancy Category: A category used to determine earthquake design loads based on the nature of the occupancy.

1.9 OSHPD: Office of Statewide Health Planning & Development, State of California

1.10 Seismic Design Category: A classification assigned to a structure based on its occupancy category and the severity of the design earthquake ground motion at the site (as defined in IBC and ASCE 7).

1.12 Seismicity

| Region of Seismicity | S_s | S_1 |
|----------------------|-----------------------------|-----------------------------|
| Very High | $\geq 1.250g$ | $\geq 0.500g$ |
| High | $< 1.250g$ $\geq 0.750g$ | $< 0.500g$ $\geq 0.300g$ |
| Moderate – High | $< 0.750g$ $\geq 0.350g$ | $< 0.300g$ $\geq 0.140g$ |
| Moderate – Low | $< 0.350g$ $\geq 0.250g$ | $< 0.140g$ $\geq 0.100g$ |
| Low | $< 0.250g$ | $< 0.100g$ |

Note: Values for S_s and S_1 at all VA sites are given in Table 4

1.13 Soft Story & Extreme Soft Story: As defined in ASCE 7, Table 12.3-2.

1.14 Spectral Response Acceleration: A parameter used to characterize the anticipated earthquake shaking at a given site. (Table 4)

S_s : Spectral acceleration parameter at short periods corresponding to the mapped maximum considered earthquake.

S_1 : Spectral acceleration parameter at a period of 1 sec corresponding to the mapped maximum considered earthquake.

2.0 GENERAL

These requirements cover all VA facilities including those of National Cemetery Administration, Veterans Benefits Administration, and Veterans Health Administration.

2.1 New Critical and Essential Facilities

All new Critical and Essential Facilities shall be designed and constructed in full compliance with the earthquake design and detailing requirements of IBC as modified in these provisions. Critical Facilities shall be assigned IBC Occupancy Category IV and Essential Facilities shall be assigned IBC Occupancy Category III. These buildings are intended to remain operational after an earthquake or other natural disaster such as tornado or hurricane as defined in ASCE 7, Section 1.5.

2.2 New Ancillary Facilities

All new Ancillary Facilities shall be designed and constructed in full compliance with the earthquake design and detailing requirements of IBC with no additional modifications. Ancillary Facilities shall be assigned to Occupancy Category II as defined in ASCE 7, Section 1.5.

2.3 Existing Facilities - Evaluation

- a. A seismic evaluation shall be conducted for existing facilities in areas of Moderate High, High, and Very High Seismicity that meet one or more of the following criteria:
 - i. Facilities selected for renovation as part of a VA classified Major Project
 - ii. Facilities selected for renovation where the area of renovation is greater than 50% of the total area
 - iii. A project is planned which significantly extends the building's useful life through alterations or repairs which total more than 30% of the replacement value of the facility.
 - iv. Facilities under consideration by VA for purchase or lease
- b. Existing Critical and Essential Facilities shall be evaluated using the procedures in ASCE 31-02 for the Immediate Occupancy Performance Level.
- c. Existing Ancillary Facilities shall be evaluated using the procedures in ASCE 31-02 for the Life Safety Performance Level.

2.4 Existing Facilities – Rehabilitation

- a. All Critical and Essential Existing Facilities shall be rehabilitated using nonlinear static procedures described in ASCE 41 to achieve the following rehabilitation objectives.

- i. Immediate occupancy performance level at BSE-1 (Basic Safety Earthquake Level 1, Earthquake Hazard Level having a probability of exceedance of 10 percent in 50 years) as defined in ASCE 41.
 - ii. Collapse Prevention performance level at BSE-2 (Basic Safety Earthquake Level 2, Earthquake Hazard Level having a probability of exceedance of 2 percent in 50 years) as defined in ASCE 41.
- b. All Ancillary Facilities shall be rehabilitated using nonlinear static procedures described in ASCE 41 using the requirements to achieve Basic Safety Objectives.

2.5 Existing Facilities Rehabilitation – Alternative Approach

An alternative approach may be permitted on a case-by-case basis upon approval by the Office of Construction & Facilities Management (CFM) for Critical and Essential Facilities to be strengthened according to procedures in ASCE 41.

2.6 Spectral Response Accelerations

The selection of Seismic Design Category for use in the design and analysis of all new and existing facilities shall be based on the spectral response accelerations shown in Table 4 after adjustment for site class effects as specified in ASCE 7. For the design of buildings in Seismic Design Category A, use ASCE 7 section 11.7. For all other Seismic Design Categories (B – F), use ASCE 7 Chapter 12: Seismic Design Requirements for Building Structures.

3.0 MODIFICATIONS TO THE REQUIREMENTS OF IBC FOR NEW CRITICAL AND ESSENTIAL FACILITIES ASSIGNED TO HIGH SEISMIC DESIGN CATEGORIES

3.1 Structural Irregularities (ASCE 7, Section 12.3.3)

For structures assigned to Seismic Design Categories D, E, or F, the following types of irregularities as defined by ASCE 7 Table 12.3-1 & 2 are not allowed:

- a. Stiffness irregularity – Soft Story
- b. Stiffness irregularity – Extreme Soft Story
- c. Weight (mass) irregularity
- d. Vertical geometric irregularity

3.2 Seismic-force-resisting-systems (ASCE 7, Table 12.2-1)

The following structural systems are permitted for new Critical and Essential Facilities assigned to Seismic Design Categories D, E, or F.

- a. Building Frame Systems
 - i. Steel eccentrically braced frames (EBF) moment resisting connections at columns away from links
 - ii. Special reinforced concrete shear walls (Building Frame)
 - iii. Special reinforced masonry shear walls (Building Frame)
 - iv. Special steel concentrically braced frames
 - v. Light frame walls with shear panels-wood structural panels/sheet steel panels (Building Frame) for structures two stories or less
 - vi. Buckling-restrained braced frames, moment-resisting beam-column connections
- b. Moment-Resisting Frame Systems, if approved by VA.
 - i. Special steel moment-resisting frames (SMRF)
 - ii. Special reinforced concrete moment-resisting frames
- c. Dual Systems
 - i. Special reinforced concrete shear walls with SMRF
 - ii. Special reinforced masonry shear walls with SMRF
 - iii. Steel EBF with SMRF
 - iv. Special steel concentrically braced frame with SMRF
 - v. Buckling-restrained braced frame

Other structural systems as permitted by the IBC for Seismic Design Categories D, E or F, including ones that employ seismic isolation and seismic damping systems are permitted subject to written approval by the VA.

3.3 Special Provisions for structures assigned to Seismic Design Categories D, E, or F.

The provisions of this section shall apply to all new Critical and Essential Facilities.

- a. Bay spacing essentially shall be equal and uniform throughout.
- b. Transfer beams or trusses supporting upper level columns shall not be used unless permitted on a case by case basis by VA.
- c. Seismic joints shall be avoided, in so far as possible. When required, they shall be specifically identified in the schematic design phase of the project and approved by VA, subject to the following provisions:
 1. Seismic joints shall be properly detailed on the working drawings;
 2. Seismic joints shall be sized based on the maximum expected displacements, considering the effects of story drift, diaphragm displacements and rotations, and a realistic approximation of element section properties. For materials designed considering the ultimate limit state, such as concrete, the stiffness representative of this state shall be used. Seismic separations shall be 125% of the separation required by ASCE 7; and
 3. Adjacent structures that are not integral with an existing structure shall be separated by not less than 2 inches per story.

3.4 Limitations on Reinforced Concrete Structures

The provisions of this section shall apply to all new Critical and Essential Facilities assigned to Seismic Design Categories D, E, or F.

- a. Prestressed concrete structural members, including pre-tensioned and post-tensioned members, and precast elements such as tilt-up wall panels, and precast beam and column elements shall not be used to resist seismic forces.
- b. Lightweight concrete shall not be used in structural members resisting earthquake forces, except in concrete floors and roof slabs used as diaphragm elements to distribute earthquake forces to vertical lateral-load resisting elements.

3.5 Limitations on Steel Structures

The provisions of this section shall apply to all new Critical and Essential Facilities assigned to Seismic Design Categories D, E, or F.

- a. Special steel moment resisting frame system shall be in compliance with Section 9 of AISC 341.
- b. Steel eccentrically braced systems shall be subject to the following special provisions:
 1. Connections of non-structural elements shall not be located in the vicinity of EBF link beams. Non-structural elements include, but are not limited to, pre-cast panel connections, elevator guide rail supports, stairs, and pipe supports, etc.

3.6 Story Drift Limitations

The calculated story drift for the construction of all new Critical and Essential Facilities assigned to Seismic Design Categories D, E, or F shall not exceed 50% of the values allowed by ASCE 7.

3.7 Exemptions

- a. No action regarding seismic rehabilitation of the seismic force resisting system of existing buildings need be undertaken in regions of moderate-low and low seismicity
- b. Non-structural components shall comply with the requirements of section 4.0.

4.0 ELEMENTS OF STRUCTURES, NONSTRUCTURAL COMPONENTS, AND EQUIPMENT SUPPORTED BY STRUCTURES FOR CRITICAL AND ESSENTIAL FACILITIES

4.1 In structures assigned to Seismic Design Category C, D, E, or F, permanent equipment and nonstructural components and their attachments, and the structure-supported attachments of permanent equipment shall be designed to resist total design forces prescribed in ASCE 7, Chapter 13 as modified by this document.

Exceptions: Seismic restraint may be omitted for the following installations:

- a. Gas and medical piping less than one inch inside diameter;
- b. Piping in boiler and mechanical equipment rooms less than 1 ¼ inch inside diameter;
- c. All other piping less than 2 ½ inch inside diameter except for automatic fire suppression systems;
- d. All electrical conduits, less than 2 ½ inch inside diameter;
- e. All rectangular air handling ducts less than six square feet in cross sectional area;
- f. All round air handling ducts less than 28 inches in diameter;
- g. All ducts suspended by hangers 12 inches or less in length from the top of the duct to the bottom of the support for the hanger;
- h. Equipment weighing less than 400 lbs, supported and attached directly on the floor; and
- i. Equipment weighing less than 20 lbs suspended from the roof or floor or hung from the wall.

4.2 In structures assigned to Seismic Design Category C, D, E, or F, permanent equipment and components are to have Special Seismic Certification in accordance with requirements of section 13.2.2 of ASCE 7 except for equipment and components that are considered rugged as listed in section 2.2 of OSHPD code application notice CAN No. 2-1708A.5, and shall comply with section 13.2.6 of ASCE 7.

5.0 SITE DATA FOR CRITICAL AND ESSENTIAL FACILITIES

5.1 New and Existing Facilities

Geologic hazards and site-specific ground-response reports shall be required for all proposed construction of new Critical and Essential Facilities assigned to Seismic Design Category C, D, E, or F and for all proposed seismic rehabilitation of existing Critical and Essential Facilities in areas of Moderate High, High, and Very High Seismicity.

Except in regions of low seismicity, the geotechnical investigation shall use appropriate methods to allow the most accurate evaluation of the site class in accordance with Chapters 20 and 21 of ASCE 7, including field shear wave velocity measurements.

5.2 Geologic Hazards Report

The purpose of the geologic hazards report shall be to identify potential geologic and seismic conditions that require detailed evaluation, and may require mitigation by the project. The report shall contain data that provide an assessment of the nature of the site and potential for earthquake damage based on preliminary investigations of the regional and site geology, subsurface conditions and the potential seismic shaking. The engineering geologic report shall not contain design criteria, but shall contain basic data to be used for a preliminary earthquake engineering evaluation of the project. The basis for seismic assessment in geologic hazards reports must be stated clearly.

The report shall include, but shall not be limited to the following:

- a. Geologic investigation;
- b. Identification of any known active and potentially active faults, both regional and local, including estimates of the peak ground accelerations that could occur at the site; and
- c. Evaluation of any slope stability problems at or near the site, liquefaction potential and settlement potential of the building site.

VA shall approve the engineering geologic hazard report prior to the preparation of the geotechnical report.

5.3 Site-Specific Ground-Response Report

The site-specific ground-response report shall present a detailed characterization of earthquake ground motions for the site. The characteristics of the expected strong ground motion to be used in design shall be determined by site evaluation studies based on geological and seismological characteristics of the site, including data given in the engineering geologic hazards report. The estimates should be derived by accepted methods of seismological practice, including Next Generation Attenuation (NGA) relationships where applicable, and fully documented in the ground response report. The level of ground motions to be developed shall be determined using the procedures in Chapter 21 of ASCE 7.

VA shall approve the site-specific ground response report prior to its adoption for project design.

6.0 COMMENTARY

Section 1.0

Section 1.2: Critical and Essential Facilities are those where most operations and functions must be able to resume immediately, while repair is required to restore some non-essential services due to a limited amount of seismic damage.

Section 2.0

Section 2.1: The seismic design requirements in the previous edition of H-18-8 did not distinguish between the Critical and Essential categories. This has now been separated and has different design requirements.

Section 3.0

Section 3.1: The design engineer shall provide multiple lines of resistance when selecting a lateral force-resisting configuration. Redundancy of frame lines is intended to avoid concentration of seismic force demands in the structure and/or foundation system. Lines of lateral force resistance shall be located at major areas of plan irregularity such as reentrant corners.

Section 3.2

The permitted structural systems listed in Section 3.2 are chosen to provide cost-effective and reliable seismic performance. Proposals to obtain written approval for other structural systems shall demonstrate the value of those systems, relative to the permitted systems, considering (a) initial construction and maintenance costs, (b) requirements for bracing non-structural components and building contents, (c) risk of economic losses and disruption to hospital functions due to earthquakes and (d) other demonstrable benefits.”

Section 3.3.c

Because seismic joints have a serious impact on exterior siding, floor joints, and interior construction and utilities, they should be avoided if at all possible.

Section 5.0

Site class is used to determine the values of short-period and 1-second design spectral accelerations, S_{DS} and S_{D1} that define Seismic Design Category in accordance with ASCE-7. Except in regions of low seismicity, an accurate evaluation of site class is to be made in accordance with Chapter 20 and Chapter 21 of ASCE 7 and is to be presented in the geotechnical evaluation report. Field shear wave velocity measurements are typically expected to provide the most reliable basis for an accurate evaluation of site class.

Although site-specific studies exist for most of VA's Critical sites, the intent of this provision is to update those studies (done in mid-seventies) for all proposed construction of new Critical and Essential Facilities assigned to moderate or high seismic design categories and all existing Critical and Essential Facilities selected for full seismic rehabilitation in areas of Moderate High, High, and Very High Seismicity.

New site-specific studies for VA facilities are to consider up-to-date information on the attenuation of earthquake ground motions with distance from the earthquake source, and other relevant seismologic and geologic information. Research sponsored by the Pacific Earthquake Engineering Research Center has led to significantly improved procedures to estimate attenuation of earthquake motions, and culminated with publication in 2008 of so-called Next Generation Attenuation (NGA) relationships for plate-boundary tectonic regimes dominated by crustal faults, such as the Western United States. It is the intent of VA requirements that new site-specific studies for VA facilities take advantage of those improved procedures and other pertinent published information on earthquake ground motion estimation, in accordance with the state of practice for the seismic design of buildings.

The standard practice of preparing a geotechnical report containing foundation recommendations, soil-bearing values, results of any necessary soil borings, etc., is still required for all VA projects.

[VA Facilities Occupancy Categories]

Table 1: Critical Facilities

| Occupancy Sub-name |
|---|
| Acute Care |
| Ambulatory Care/ Outpatient Clinic |
| Animal Facility |
| Boiler Plants |
| Communications Center |
| Emergency Command Center |
| Emergency Generator |
| Fire/Police Station |
| Hazardous Material Storage |
| Hospital |
| Information Technology |
| Medical Gas Storage |
| Medical Research/Records |
| National Continuity of Operation Center |
| Security & Law Enforcement |
| Water Tower, Utility Supply Storage Structure |

Table 2: Essential Facilities

| Occupancy Sub-name |
|-------------------------------|
| Consolidate Mail-Out Pharmacy |
| Dietetics |
| Domiciliary |
| Drug/Alcohol Rehabilitation |
| Long Term Care |
| Medical Equipment Storage |
| Mental Health - Inpatient |
| Psychiatric Care Facility |
| Rehabilitation Medicine |

Table 3: Ancillary Facilities

| Occupancy Sub-name | |
|--|--|
| Accessory Non-Building Structure | Maintenance Facility (Shops) |
| Auditorium | Maintenance Storage (Equipment) |
| Biomedical Eng. (equip. & wheelchair repair) | Materials Management Storage |
| Canteen-Cafeteria | Office |
| Canteen-Retail Store | School |
| Cemetery Building | Parking Garage |
| Chapel | Plant Outbuilding |
| Child Care | Post Office |
| Clinical Service Administration Office | Recreational |
| Community-Based Outpatient Clinic | Student Housing |
| Connecting Corridor-Concourse, and Bridge | Temporary Building |
| Credit Union | Toilets (Outhouse) |
| General Administration Office | Training, Education |
| Greenhouse | Veterans Services |
| Quarter (Residential) | Warehouse |
| Laundry | Waste Management (Incinerator & Recycle) |
| Library/Museum | Waste Storage |

Note: The Critical, Essential and Ancillary Facilities Tables are developed to keep in line with three occupancy categories listed in IBC.

**Table 4
Spectral Response Accelerations at VA Facilities**

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|----------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Abraham Lincoln | 915 | IL | 0.188 | 0.068 | L |
| Albany | 528A8 | NY | 0.230 | 0.069 | L |
| Albuquerque | 501 | NM | 0.561 | 0.169 | MH |
| Alexandria | 502 | LA | 0.127 | 0.060 | L |
| Alexandria | 825 | LA | 0.128 | 0.061 | L |
| Alexandria | 826 | VA | 0.153 | 0.050 | L |
| Allen Park | 553A | MI | 0.126 | 0.045 | L |
| Alton | 800 | IL | 0.484 | 0.149 | MH |
| Altoona | 503 | PA | 0.144 | 0.049 | L |
| Amarillo | 504 | TX | 0.175 | 0.043 | L |
| American Lake | 663A4 | WA | 1.194 | 0.417 | H |
| Anchorage | 463 | AK | 1.502 | 0.561 | VH |
| Ann Arbor | 506 | MI | 0.120 | 0.045 | L |
| Annapolis | 801 | MD | 0.155 | 0.050 | L |
| Asheville | 637 | NC | 0.388 | 0.106 | MH |
| Aspinwall | 646A4 | PA | 0.125 | 0.048 | L |
| Atlanta | 508 | GA | 0.230 | 0.086 | L |
| Augusta | 509 | GA | 0.372 | 0.114 | MH |
| Augusta (Lenwood) | 509A0 | GA | 0.378 | 0.115 | MH |
| Balls Bluff | 827 | VA | 0.160 | 0.051 | L |
| Baltimore | 512 | MD | 0.170 | 0.051 | L |
| Baltimore | 802 | MD | 0.170 | 0.051 | L |
| Baltimore/Loch Raven | 512GD | MD | 0.170 | 0.051 | L |
| Barrancas | 828 | FL | 0.099 | 0.048 | L |
| Batavia | 528A4 | NY | 0.266 | 0.060 | ML |
| Bath | 803 | NY | 0.165 | 0.053 | L |
| Bath | 528A6 | NY | 0.165 | 0.053 | L |
| Baton Rouge | 829 | LA | 0.121 | 0.053 | L |
| Battle Creek | 515 | MI | 0.112 | 0.047 | L |
| Bay Pines | 516 | FL | 0.078 | 0.032 | L |
| Bay Pines | 830 | FL | 0.078 | 0.032 | L |
| Beaufort | 831 | SC | 0.693 | 0.183 | MH |
| Beckley | 517 | WV | 0.263 | 0.076 | ML |
| Bedford | 518 | MA | 0.288 | 0.070 | ML |
| Beverly | 804 | NJ | 0.273 | 0.060 | ML |
| Big Spring | 519 | TX | 0.111 | 0.031 | L |
| Biloxi | 520 | MS | 0.119 | 0.052 | L |
| Biloxi | 832 | MS | 0.117 | 0.052 | L |
| Birmingham | 521 | AL | 0.303 | 0.096 | ML |
| Black Hills | 884 | SD | 0.151 | 0.042 | L |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|-----------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Boise | 531 | ID | 0.312 | 0.106 | ML |
| Bonham | 549A4 | TX | 0.161 | 0.062 | L |
| Boston | 523 | MA | 0.272 | 0.067 | ML |
| Brevard | 673GA | FL | 0.083 | 0.035 | L |
| Brockton | 523A5 | MA | 0.251 | 0.063 | ML |
| Bronx | 526 | NY | 0.361 | 0.070 | MH |
| Brooklyn | 630A4 | NY | 0.353 | 0.069 | MH |
| Buffalo | 528 | NY | 0.282 | 0.059 | ML |
| Butler | 529 | PA | 0.128 | 0.048 | L |
| Calverton | 805 | NY | 0.209 | 0.056 | L |
| Camp Butler | 806 | IL | 0.268 | 0.105 | L |
| Camp Nelson | 833 | KY | 0.225 | 0.089 | ML |
| Canandaigua | 528A5 | NY | 0.187 | 0.057 | L |
| Castle Point | 620A4 | NY | 0.280 | 0.067 | ML |
| Cave Hill | 834 | KY | 0.247 | 0.103 | ML |
| Charleston | 534 | SC | 1.443 | 0.355 | VH |
| Chattanooga | 835 | TN | 0.474 | 0.116 | MH |
| Cheyenne | 442 | WY | 0.192 | 0.053 | L |
| Chicago (Lakeside) | 537GD | IL | 0.161 | 0.059 | L |
| Chicago (Westside) | 537 | IL | 0.166 | 0.060 | L |
| Chillicothe | 538 | OH | 0.157 | 0.064 | L |
| Cincinnati | 539 | OH | 0.176 | 0.075 | L |
| City Point | 836 | VA | 0.187 | 0.058 | L |
| Clarksburg | 540 | WV | 0.187 | 0.068 | L |
| Cleveland/Brecksville | 541A0 | OH | 0.197 | 0.052 | L |
| Cleveland/Wade Park | 541 | OH | 0.197 | 0.052 | L |
| Coatesville | 542 | PA | 0.274 | 0.060 | ML |
| Cold Harbor | 837 | VA | 0.206 | 0.058 | L |
| Columbia | 589A4 | MO | 0.198 | 0.088 | L |
| Columbia | 544 | SC | 0.572 | 0.153 | MH |
| Corinth | 838 | MS | 0.501 | 0.169 | MH |
| Crown Hill | 807 | IN | 0.190 | 0.083 | L |
| Culpeper | 839 | VA | 0.193 | 0.057 | L |
| Cypress Hills | 808 | NY | 0.358 | 0.069 | MH |
| Dallas | 549 | TX | 0.113 | 0.049 | L |
| Dallas/Fort Worth | 916 | TX | 0.116 | 0.050 | L |
| Danville | 550 | IL | 0.224 | 0.091 | L |
| Danville | 809 | IL | 0.224 | 0.091 | L |
| Danville | 840 | KY | 0.219 | 0.092 | L |
| Danville | 841 | VA | 0.196 | 0.074 | L |
| Dayton | 552 | OH | 0.186 | 0.069 | L |
| Dayton | 810 | OH | 0.206 | 0.070 | L |
| Denver | 554 | CO | 0.214 | 0.056 | L |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

**Table 4 (continued)
Spectral Response Accelerations at VA Facilities**

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Des Moines | 636A6 | IA | 0.075 | 0.043 | L |
| Detroit | 553 | MI | 0.121 | 0.045 | L |
| Dublin | 557 | GA | 0.215 | 0.083 | L |
| Durham | 558 | NC | 0.198 | 0.078 | L |
| Eagle Point | 906 | OR | 0.583 | 0.255 | MH |
| East Orange | 561 | NJ | 0.363 | 0.071 | MH |
| El Paso | 756 | TX | 0.333 | 0.107 | ML |
| Erie | 562 | PA | 0.163 | 0.049 | L |
| Fargo | 437 | ND | 0.074 | 0.021 | L |
| Fayetteville | 564 | AR | 0.207 | 0.091 | L |
| Fayetteville | 565 | NC | 0.297 | 0.101 | ML |
| Fayetteville | 842 | AR | 0.207 | 0.091 | L |
| Finn's Point | 811 | NJ | 0.232 | 0.055 | L |
| Florence | 843 | SC | 0.728 | 0.198 | MH |
| Florida | 911 | FL | 0.090 | 0.038 | L |
| Fort Bayard | 885 | NM | 0.272 | 0.081 | ML |
| Fort Bliss | 886 | TX | 0.336 | 0.109 | MH |
| Fort Custer | 909 | MI | 0.109 | 0.047 | L |
| Fort Gibson | 844 | OK | 0.187 | 0.075 | L |
| Fort Harrison | 436 | MT | 0.746 | 0.222 | MH |
| Fort Harrison | 845 | VA | 0.225 | 0.060 | L |
| Fort Howard | 512GF | MD | 0.167 | 0.050 | L |
| Fort Leavenworth | 887 | KS | 0.129 | 0.055 | L |
| Fort Logan | 888 | CO | 0.219 | 0.057 | L |
| Fort Lyon | 567 | CO | 0.165 | 0.050 | L |
| Fort Lyon | 889 | CO | 0.165 | 0.050 | L |
| Fort McPherson | 890 | NE | 0.094 | 0.033 | L |
| Fort Meade | 568 | SD | 0.206 | 0.051 | L |
| Fort Meade | 891 | SD | 0.206 | 0.051 | L |
| Fort Mitchell | 908 | AL | 0.142 | 0.066 | L |
| Fort Richardson | 910 | AK | 1.502 | 0.560 | VH |
| Fort Rosecrans | 892 | CA | 1.569 | 0.614 | VH |
| Fort Sam Houston | 846 | TX | 0.105 | 0.029 | L |
| Fort Scott | 893 | KS | 0.128 | 0.066 | L |
| Fort Sill | 920 | OK | 0.373 | 0.085 | MH |
| Fort Smith | 847 | AR | 0.209 | 0.088 | L |
| Fort Snelling | 894 | MN | 0.061 | 0.027 | L |
| Fort Thomas | 539A | OH | 0.150 | 0.058 | L |
| Fort Wayne | 610A4 | IN | 0.150 | 0.059 | L |
| Fresno | 570 | CA | 0.501 | 0.222 | MH |
| Gainesville | 573 | FL | 0.107 | 0.048 | L |
| Glendale | 848 | VA | 0.225 | 0.060 | L |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|----------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Golden Gate | 895 | CA | 2.218 | 1.266 | VH |
| Grafton | 812 | WV | 0.139 | 0.054 | L |
| Grand Island | 636A4 | NE | 0.129 | 0.039 | L |
| Grand Junction | 575 | CO | 0.287 | 0.067 | ML |
| Gulfport | 520A0 | MS | 0.119 | 0.052 | L |
| Hampton | 590 | VA | 0.120 | 0.048 | L |
| Hampton | 849 | VA | 0.122 | 0.049 | L |
| Hampton (VAMC) | 850 | VA | 0.122 | 0.049 | L |
| Hines | 578 | IL | 0.173 | 0.058 | L |
| Hines VBA | 201 | IL | 0.173 | 0.058 | L |
| Honolulu ** | 459 | HI | 0.613 | 0.178 | MH |
| Hot Springs | 896 | SD | 0.207 | 0.049 | L |
| Hot Springs | 568A4 | SD | 0.207 | 0.049 | L |
| Houston | 580 | TX | 0.087 | 0.036 | L |
| Houston | 851 | TX | 0.088 | 0.036 | L |
| Houston VBA | 362 | TX | 0.087 | 0.036 | L |
| Huntington | 581 | WV | 0.192 | 0.071 | L |
| Indianapolis | 583 | IN | 0.192 | 0.083 | L |
| Indianapolis (CS Rd) | 583A4 | IN | 0.192 | 0.083 | L |
| Indiantown Gap | 813 | PA | 0.219 | 0.056 | L |
| Iowa City | 636A8 | IA | 0.100 | 0.052 | L |
| Iron Mountain | 585 | MI | 0.058 | 0.026 | L |
| Jackson | 586 | MS | 0.194 | 0.086 | L |
| Jackson VBA | 323 | MS | 0.194 | 0.086 | L |
| Jefferson Barracks | 852 | MO | 0.580 | 0.167 | MH |
| Jefferson City | 853 | MO | 0.236 | 0.100 | ML |
| Kansas City | 589 | MO | 0.127 | 0.059 | L |
| Keokuk | 814 | IA | 0.148 | 0.072 | L |
| Kerrville | 854 | TX | 0.074 | 0.026 | L |
| Kerrville | 671A4 | TX | 0.074 | 0.026 | L |
| Knoxville | 636A7 | IA | 0.083 | 0.048 | L |
| Knoxville | 855 | TN | 0.519 | 0.118 | MH |
| Lake City | 573A4 | FL | 0.122 | 0.054 | L |
| Las Vegas | 593 | NV | 0.549 | 0.171 | MH |
| Leavenworth | 897 | KS | 0.129 | 0.055 | L |
| Leavenworth | 589A6 | KS | 0.129 | 0.055 | L |
| Lebanon | 856 | KY | 0.225 | 0.098 | L |
| Lebanon | 595 | PA | 0.228 | 0.057 | L |
| Lexington | 857 | KY | 0.224 | 0.088 | L |
| Lexington (CD) | 596A4 | KY | 0.229 | 0.087 | L |
| Lexington (LD) | 596 | KY | 0.229 | 0.087 | L |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Lincoln | 636A5 | NE | 0.177 | 0.046 | L |
| Little Rock | 598 | AR | 0.494 | 0.160 | MH |
| Little Rock | 858 | AR | 0.507 | 0.164 | MH |
| Livermore | 640A4 | CA | 1.590 | 0.602 | VH |
| Loma Linda | 605 | CA | 1.761 | 0.610 | VH |
| Long Beach | 600 | CA | 2.022 | 0.853 | VH |
| Long Island | 815 | NY | 0.293 | 0.063 | ML |
| Los Angeles | 898 | CA | 1.656 | 0.590 | VH |
| Los Angeles | 691GE | CA | 2.232 | 0.766 | VH |
| Loudon Park | 816 | MD | 0.170 | 0.051 | L |
| Louisville | 603 | KY | 0.246 | 0.102 | ML |
| Lyons | 561A4 | NJ | 0.347 | 0.069 | ML |
| Madison | 607 | WI | 0.104 | 0.044 | L |
| Manchester | 608 | NH | 0.351 | 0.080 | MH |
| Marietta | 859 | GA | 0.251 | 0.089 | ML |
| Marion | 657A5 | IL | 1.118 | 0.306 | H |
| Marion | 610 | IN | 0.151 | 0.067 | L |
| Marion | 817 | IN | 0.151 | 0.067 | L |
| Marlin | 674A5 | TX | 0.090 | 0.040 | L |
| Martinez/NCSC | 612 | CA | 1.575 | 0.600 | VH |
| Martinsburg | 613 | WV | 0.167 | 0.052 | L |
| Massachusetts | 818 | MA | 0.211 | 0.056 | L |
| McClellan | 612GH | CA | 0.487 | 0.221 | MH |
| Memphis | 614 | TN | 1.289 | 0.354 | VH |
| Memphis | 860 | TN | 1.289 | 0.354 | VH |
| Menlo Park | 640A0 | CA | 1.792 | 0.793 | VH |
| Miami | 546 | FL | 0.051 | 0.019 | L |
| Miles City | 436GJ | MT | 0.099 | 0.034 | L |
| Mill Springs | 861 | KY | 0.234 | 0.096 | L |
| Milwaukee (Wood) | 695 | WI | 0.108 | 0.045 | L |
| Minneapolis | 618 | MN | 0.060 | 0.027 | L |
| Mobile | 862 | AL | 0.117 | 0.053 | L |
| Montgomery | 619 | AL | 0.154 | 0.069 | L |
| Montgomery VBA | 322 | AL | 0.154 | 0.069 | L |
| Montrose | 620 | NY | 0.332 | 0.070 | ML |
| Mound City | 863 | IL | 3.390 | 1.313 | VH |
| Mountain Home | 621 | TN | 0.392 | 0.102 | MH |
| Mountain Home | 864 | TN | 0.392 | 0.102 | MH |
| Murfreesboro | 626A4 | TN | 0.290 | 0.116 | ML |
| Muskogee | 623 | OK | 0.185 | 0.074 | L |
| Nashville | 626 | TN | 0.345 | 0.133 | ML |
| Nashville | 865 | TN | 0.345 | 0.133 | ML |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|------------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Natchez | 866 | MS | 0.141 | 0.067 | L |
| NCA Operations Support | 786 | VA | 0.189 | 0.066 | L |
| New Albany | 867 | IN | 0.250 | 0.103 | ML |
| New Bern | 868 | NC | 0.162 | 0.065 | L |
| New Orleans | 629 | LA | 0.110 | 0.048 | L |
| New York | 630 | NY | 0.361 | 0.070 | MH |
| Newington | 689A4 | CT | 0.240 | 0.063 | L |
| NMCA | 914 | AZ | 0.178 | 0.061 | L |
| NMCP** | 899 | HI | 0.613 | 0.178 | MH |
| North Chicago | 556 | IL | 0.141 | 0.053 | L |
| North Little Rock | 598A0 | AR | 0.514 | 0.165 | MH |
| Northampton | 631 | MA | 0.224 | 0.066 | LL |
| Northport | 632 | NY | 0.286 | 0.064 | ML |
| Oklahoma City | 635 | OK | 0.336 | 0.074 | ML |
| Omaha | 636 | NE | 0.123 | 0.042 | L |
| Orlando | 673BY | FL | 0.096 | 0.038 | L |
| Palo Alto | 640 | CA | 1.959 | 0.827 | VH |
| Perry Point | 512A5 | MD | 0.216 | 0.054 | L |
| Philadelphia | 642 | PA | 0.271 | 0.060 | ML |
| Philadelphia | 819 | PA | 0.281 | 0.062 | ML |
| Phoenix | 644 | AZ | 0.182 | 0.062 | L |
| Pittsburgh (HD) | 646A5 | PA | 0.125 | 0.049 | L |
| Pittsburgh (UD) | 646 | PA | 0.125 | 0.048 | L |
| Poplar Bluff | 657A4 | MO | 1.100 | 0.303 | H |
| Port Hudson | 870 | LA | 0.123 | 0.055 | L |
| Portland | 648 | OR | 0.984 | 0.345 | H |
| Prescott | 649 | AZ | 0.342 | 0.100 | ML |
| Prescott | 900 | AZ | 0.350 | 0.102 | MH |
| Providence | 650 | RI | 0.234 | 0.061 | L |
| Quantico | 872 | VA | 0.162 | 0.052 | L |
| Quincy | 820 | IL | 0.181 | 0.082 | L |
| Raleigh | 873 | NC | 0.202 | 0.079 | L |
| Reno | 654 | NV | 1.500 | 0.600 | VH |
| Richmond | 652 | VA | 0.225 | 0.060 | L |
| Richmond | 874 | VA | 0.225 | 0.060 | L |
| Riverside** | 901 | CA | 1.500 | 0.600 | VH |
| Rock Island | 821 | IL | 0.131 | 0.060 | L |
| Roseburg | 653 | OR | 0.830 | 0.422 | VH |
| Roseburg | 902 | OR | 0.830 | 0.422 | H |
| Sacramento NCHCS | 612A4 | CA | 0.464 | 0.214 | MH |
| Saginaw** | 655 | MI | 0.080 | 0.037 | L |
| Salem | 658 | VA | 0.264 | 0.076 | ML |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S_1 (new) | Seismicity |
|--------------------|-------------------|-------|-------------|-------------|------------|
| Salisbury | 659 | NC | 0.261 | 0.094 | ML |
| Salisbury | 876 | NC | 0.261 | 0.094 | ML |
| Salt Lake City | 660 | UT | 1.577 | 0.625 | VH |
| San Antonio | 671 | TX | 0.105 | 0.031 | L |
| San Antonio | 877 | TX | 0.105 | 0.029 | L |
| San Diego | 664 | CA | 1.562 | 0.602 | VH |
| San Francisco | 662 | CA | 1.761 | 0.901 | VH |
| San Francisco | 903 | CA | 1.500 | 0.668 | VH |
| San Joaquin Valley | 913 | CA | 1.825 | 0.600 | VH |
| San Juan | 672 | PR | 0.898 | 0.314 | H |
| Santa Fe | 904 | NM | 0.484 | 0.156 | MH |
| Saratoga | 917 | NY | 0.252 | 0.074 | ML |
| Seattle | 663 | WA | 1.551 | 0.534 | VH |
| Sepulveda | 691A4 | CA | 2.042 | 0.727 | VH |
| Seven Pines | 878 | VA | 0.198 | 0.057 | L |
| Sheridan** | 666 | WY | 0.271 | 0.060 | ML |
| Shreveport | 667 | LA | 0.153 | 0.069 | L |
| Sioux Falls | 438 | SD | 0.111 | 0.034 | L |
| Sitka | 905 | AK | 0.965 | 0.497 | H |
| Somerville AMS | 796 | NJ | 0.325 | 0.067 | ML |
| Spokane | 668 | WA | 0.404 | 0.114 | MH |
| Springfield | 879 | MO | 0.221 | 0.096 | L |
| St. Albans | 630A5 | NY | 0.338 | 0.067 | ML |
| St. Augustine | 875 | FL | 0.126 | 0.053 | L |
| St. Cloud | 656 | MN | 0.079 | 0.022 | L |
| St. Louis (JB) | 657A0 | MO | 0.596 | 0.171 | MH |
| St. Louis (JC) | 657 | MO | 0.596 | 0.171 | MH |
| St. Petersburg VBA | 317 | FL | 0.078 | 0.032 | L |
| Staunton | 880 | VA | 0.211 | 0.063 | L |
| Syracuse | 528A7 | NY | 0.180 | 0.061 | L |
| Tahoma | 919 | WA | 1.284 | 0.436 | VH |
| Tampa | 673 | FL | 0.077 | 0.032 | L |
| Temple | 674 | TX | 0.082 | 0.037 | L |
| Togus | 402 | ME | 0.292 | 0.077 | ML |
| Togus | 822 | ME | 0.292 | 0.077 | ML |
| Tomah | 676 | WI | 0.067 | 0.034 | L |
| Topeka | 589A5 | KS | 0.157 | 0.054 | L |
| Tucson | 678 | AZ | 0.287 | 0.081 | ML |
| Tuscaloosa | 679 | AL | 0.268 | 0.093 | ML |
| Tuskegee | 619A4 | AL | 0.150 | 0.068 | L |
| Vancouver | 648A4 | WA | 0.918 | 0.325 | H |
| Waco | 674A4 | TX | 0.087 | 0.040 | L |

Note: Values of S_s & S_1 have been obtained from the design maps of Chapter 22 of ASCE 7.

Table 4 (continued)
Spectral Response Accelerations at VA Facilities

| Site | Med Center Number | State | S_s (new) | S₁ (new) | Seismicity |
|----------------------|--------------------------|--------------|----------------------------|----------------------------|-------------------|
| Walla Walla | 687 | WA | 0.460 | 0.131 | MH |
| Washington, DC | 688 | DC | 0.153 | 0.050 | L |
| West Haven | 689 | CT | 0.244 | 0.062 | L |
| West Los Angeles | 691 | CA | 1.867 | 0.636 | VH |
| West Palm Beach | 548 | FL | 0.060 | 0.025 | L |
| West Roxbury | 523A4 | MA | 0.265 | 0.066 | ML |
| West Virginia | 912 | WV | 0.139 | 0.054 | L |
| White City | 692 | OR | 0.585 | 0.264 | MH |
| White River Junction | 405 | VT | 0.299 | 0.081 | ML |
| Wichita | 589A7 | KS | 0.135 | 0.051 | L |
| Wilkes-Barre | 693 | PA | 0.199 | 0.057 | L |
| Willamette | 907 | OR | 0.987 | 0.348 | H |
| Wilmington | 460 | DE | 0.260 | 0.058 | ML |
| Wilmington | 881 | NC | 0.296 | 0.098 | ML |
| Winchester | 882 | VA | 0.167 | 0.054 | L |
| Wood | 823 | WI | 0.107 | 0.044 | L |
| Woodlawn | 824 | NY | 0.153 | 0.053 | L |
| Zachary Taylor | 883 | KY | 0.247 | 0.103 | ML |

Note: Values of S_s & S₁ have been obtained from the design maps of Chapter 22 of ASCE 7.

August 2013

Department of Veterans Affairs Seismic Zone Map

H-18-8

Note: Seismicity is based on the spectral acceleration listed in ASCE- Latest Edition

